

NEBRASKA ADMINISTRATIVE CODE

TITLE 229 - DEPARTMENT OF LABOR

CHAPTER 8 - VALIDITY OF INSPECTION CERTIFICATES

001. This chapter is adopted pursuant to *Neb. Rev. Stat. §48-727*.
002. Except as provided in §003 of this chapter, a Certificate of Inspection for a boiler or pressure vessel, for which a Certificate of Inspection has not been previously issued, shall be valid until the date of the next inspection required under 229 NAC 5. A Certificate of Inspection for a boiler or pressure vessel which has been previously inspected and registered with the state shall be valid until the date the next scheduled inspection is required under 229 NAC 5 or as noted on the Certificate of Inspection. For boilers or pressure vessels where only the ownership has changed or the owner-user has changed names the Certificate of Inspection shall be valid until the date of the next inspection required under 229 NAC 5.
003. A Certificate of Inspection issued in accordance with *Neb. Rev. Stat. §48-722* and 229 NAC 7 shall be valid until expiration unless some defect or condition affecting the safety of the boiler or pressure vessel for which it was issued is discovered, and such defect or condition is not repaired. Failure to repair a defect or condition affecting the safety of the boiler or pressure vessel shall be cause for revocation of such boiler's or pressure vessel's Certificate of Inspection. Any boiler or pressure vessel that has had its Certificate of Inspection revoked for the reason described above shall not be operated until the boiler or pressure vessel has been repaired, inspected, and the Certificate of Inspection reissued.